

Declaration of Conformity



Applicant: Victron Energy B.V.
De Paal 35
1351 JG Almere
The Netherlands

Product type: Battery Inverter

Model: Phoenix Inverter 48/5000 230V VE.Bus

Rating: Input voltage: 38-66 Vdc;
Input current: 118 Adc
Output voltage: 225-235 Vac 50 Hz;
Output current: 18.5 Aac;
Output apparent power: 5000 VA;
Output active power: 4000 W

A representative test sample of above stated model passed the tests according to:

Standard: IEC 62109-1:2010, EN 62109-1:2010
IEC 60335-2-29 (fourth Edition) +A1:2004 +A2:2009 for use in
conjunction with IEC 60335-1:2010 (fifth Edition) +A1:2013
EN 60335-2-29:2004 + A2:2009 with EN 60335-1:2012 +
A11:2014

Report no: 19PP350-01 and 19PP350-02

Certificate no: 20-018-00

Date of issue: 2020-02-19

DECLARATION

Kiwa Primara GmbH
Gewerbestraße 28
87600 Kaufbeuren
Germany
Tel. +49 8341 99726-0
info@primara.net
www.kiwa.de

Michael Schugg

